

Kitemark™ Certificate

This is to certify that:

Systemair Sdn. Bhd
Lot 3692
Kampong Jaya Industrial Area
Jalan Kusta, 13 1/2 Miles
Sungai Buloh
Selangor D.E.
47000
Malaysia

Holds Certificate Number:

KM 622130

In respect of:

BS EN 12101-3: 2015
Powered smoke and heat exhaust ventilators

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Chris Lewis - Certification Director, Product Certification

First Issued: 2014-10-31

Latest Issue: 2018-02-06

Effective Date: 2018-02-06

Expiry Date: 2021-02-05



003

Page: 1 of 3

...making excellence a habit.™

Kitemark™ Certificate

No. KM 622130

BS EN 12101-3:2015 - Certified product scope:

AXC Axial fan range (CMG Motor)	AXC 315 (B)	AXC 355 (B)	AXC 400 (B)
	AXC 450 (B)	AXC 500 (B)	AXC 560 (B)
	AXC 630 (B)	AXC 710 (B)	AXC 800 (B)
	AXC 900 (B)	AXC 1000 (B)	AXC 1120 (B)
	AXC 1250 (B)	AXC 1400 (B)	AXC 1600 (B)
Response Delay	N/A		
Resistance to Fire class	F300 (Tested to 300°C, 120mins)		
Motor Rating	Class H		
Ancillaries	Mounting brackets – Vertical – MFA Mounting feet – Horizontal Flexible connection – EV-H Matching flanges Bellmouth inlets (mild steel, stainless steel – EFD-F Range) Silencers (mild steel, stainless steel – RS Range)		
BSRIA range report: 53580/4 refers			

AJR Axial fan range	1 & 2 speed models (Leroy Somer motors)		
	AJR 315-TR-2	AJR 355-TR-2	AJR 400-TR-2
	AJR 315-TR-2/4	AJR 355-TR-2/4	AJR 400-TR-2/4
	AJ8 315-TR-2**	AJ8 355-TR-2**	AJ8 400-TR-2**
	AJ8 315-TR-2/4**	AJ8 355-TR-2/4**	AJ8 400-TR-2/4**
	CMG motors		
	AJ8 315**	AJ8 355**	AJ8 400**
	AJR 315	AJR 355	AJR 400
Response Delay	N/A		
Resistance to Fire class	F300 (300°C, 60mins) *		
Motor Rating	Class H		
Ancillaries	Ziehl Abegg FXDM frequency converter		
	Round silencer		
	Octagonal silencer**		
Applus reports: 10/101420 & 13/4971-2181 refer.			

*tested 300°C, 120mins.

First Issued: 2014-10-31

Latest Issue: 2018-02-06

Effective Date: 2018-02-06

Expiry Date: 2021-02-05

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 622130

BS EN 12101-3:2015 - Certified product scope:

AJR Axial fan range	Model numbers (WEG motors)		
	AJ8 315**	AJ8 355**	AJ8 400**
	AJR 315	AJR 355	AJR 400
Response Delay	N/A		
Resistance to Fire class	F400 (400°C, 120mins) *		
Motor Rating	Class H		
Ancillaries	16A External terminal box		
	AB55621F4 GAVE Switch		
	Octagonal silencer**		
	Protection grid		
Applus report: 15/4971-2781 refers.			

*tested 400°C, 120mins.

First Issued: 2014-10-31
Latest Issue: 2018-02-06

Effective Date: 2018-02-06
Expiry Date: 2021-02-05

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.